



**Woodard
& Curran**

Improving Resiliency and Life Cycle Costs of Nutrient Reduction

Florida Stormwater Association

Annual Conference

June 16, 2023

Scott Shannon, PE

Josh Schmitz, PE




NuRF Location



Lake Apopka

Orlando



NuRF Layout

Sludge Handling



Dewatering



Conveyance




Dredging



Settling


Alum Injection



Inflow Station



Outflow Station




LCWA Objective and Historical Flows

“To reliably treat the entire volume of water flowing through the Apopka-Beauclair Canal, sustaining up to a maximum flow rate of 300 cubic feet per second”

| Flow Regime | Flow Range (cfs) | Number of Days | Days (%) |
|--------------------|------------------|----------------|----------|
| Low | 1 to 49 | 1470 | 71.8% |
| Mid | 50 to 149 | 310 | 15.2% |
| High | 150 to 299 | 266 | 11.4% |
| Very High (Design) | > 299 | 32 | 1.6% |


Capacity of 300 cfs treats entire canal flow greater than 98% of the time.

Operational History (2010-2021)



March 2009 – August 2017
Average Flow Rate: 18 cfs
Total Throughput: 16.6 Billion gallons



Operational History (2010-2021)



March 2009 – August 2017
Average Flow Rate: 18 cfs
Total Throughput: 16.6 Billion gallons

September 2009 – June 2021
Average Flow Rate: 64 cfs
Throughput: 57.6 Billion gallons
A-B Canal: 85.4 Billion gallons


Hurricane Irma (2017) and Aftermath



Operational Impacts



Capacity of NuRF Processes



Inflow/Outflow capacity assumed capable of 500+ cfs. Max observed historical flow of Apopka-Beauclair Canal is 754 cfs.

Alum injection capacity (300 cfs) limited by 30 gpm max output of one alum pump. Fixed dose rate of 13 mg Al / liter equates to 1 gpm per 10 cfs. Assumes sufficient mixing.

Settling pond capacity (450 cfs) based on max average flow rate sustained over 10-day period, starting with fully dredged pond, until floc accumulation exceeds 1.5 hr detention time requirement at 300 cfs, without dredging.

Dredging capacity (222 cfs) based on each dredge (2) pumping at 600 gpm capacity for eight hours per day, and that such capacity just balances out floc production assuming dredge mix is 50% floc by volume.


Floc Conveyance & Storage capacity (111 cfs) based on dredge pipe capacity of 600 gpm limited to one dredge operating at a time, reducing dredge capacity above by half.

Dewatering capacity (74 cfs) based on 400 gpm of dredge material (50% floc) throughput of single centrifuge operating eight hours per day.


Sludge Handling capacity (99 cfs) based on reported output of 18 cy sludge from centrifuge when operating continuously at 400 gpm for eight hours, and staff reported capability to dispose 24 cy on site per 8 hr shift.

NuRF Process Diagram

Water Treatment Capacity = 300 cfs



Residuals Processing Capacity = 74 cfs



How can we increase capacity
and improve resiliency?

Primary Inflow Station

- ▶ Implement automated, self-cleaning screening system, such as a bar rack with traversing grab rake
- ▶ Will screen out floating and suspended debris
- ▶ Protects new dredges and allows them to operate within design conditions



Alum Injection and Mixing

- ▶ Proceed with carrier water/alum and dispersed injection system to improve mixing
- ▶ Establish the primary alum feed at the intake structure with secondary feeds immediately upstream of the floc ponds
- ▶ Implement real time phosphorus monitoring to enable reduced alum usage



Dredging

- ▶ Proceed with planned installation of new dredges
- ▶ The new dredges should be onboarded in a manner that ensures complete pond coverage and a consistent floc free of grit to the dewatering equipment, including an effective sand and grit prevention system.
- ▶ If the new dredges are unable to prevent sand and grit from adversely affecting the dewatering process, a dedicated grit removal technology should then be evaluated.
- ▶ Repair of dredge controls and rail guidance should be completed prior to dredges being activated



Dewatering

- ▶ Defer assessment of need for dewatering system expansion or improvements until prior improvements are completed, because these will change floc characteristics.
- ▶ Assessment should evaluate grit removal (if still necessary), polymer applicability, and type of additional capital equipment needed.



Dewatering Alternatives Evaluation

| Estimated Daily Dewatering Rate (cfs) | 1 Centrifuge with Increased Shifts | Potential Improvement to Floc Feed Density with 1 Centrifuge | 2 Centrifuges with Increased Shifts | Potential Improvement to Floc Feed Density with 2 Centrifuges | Duration to Net Reduction in Floc after Irma (days) | Net Reduction in Floc < 10 days, or 300 cfs Dewatering? |
|---------------------------------------|------------------------------------|--|-------------------------------------|---|---|---|
| 37 | 1 centrifuge, 1 shift | No efficiency improvement | | | > 1,238 | No |
| 74 | 1 centrifuge, 1 shift | 100% efficiency improvement | | | 967 | No |
| 74 | 1 centrifuge, 2 shifts | No efficiency improvement | 2 centrifuge, 1 shift | No efficiency improvement | 967 | No |
| 111 | 1 centrifuge, 3 shifts | No efficiency improvement | | | 486 | No |
| 148 | 1 centrifuge, 2 shifts | 100% efficiency improvement | 2 centrifuge, 1 shift | 100% efficiency improvement | 187 | No |
| 148 | | | 2 centrifuge, 2 shift | No efficiency improvement | 187 | No |
| 222 | 1 centrifuge, 3 shifts | 100% efficiency improvement | | | 88 | No |
| 222 | | | 2 centrifuge, 3 shifts | No efficiency improvement | 88 | No |
| 296 | | | 2 centrifuge, 2 shifts | 100% efficiency improvement | 4 | Yes |
| 444 | | | 2 centrifuge, 3 shifts | 100% efficiency improvement | 0 | Yes |

On-Site Sludge Handling

- ▶ LCWA's highest priority should be to identify and arrange for an off-site disposal option and begin hauling dewatered sludge off-site as soon as possible.
- ▶ Defer onsite sludge handling improvements to account for long-term disposal and new operational requirements




Instrumentation and Controls

- ▶ Replace damaged controls and implement a single communication platform for ease of operations, automation and expandability.
- ▶ Evaluate new centrifuge control hardware, software, and programming to optimize output based on feed density (after dredging improvements have been implemented)



Projected Capacity Improvements



Inflow/Outflow capacity assumed capable of 500+ cfs. Max observed historical flow of Apopka-Beauclair Canal is 754.

Alum injection capacity (600 cfs) limited by 30 gpm max output of two alum pumps operating simultaneously. Fixed dose rate of 13 mg Al / liter equates to 1 gpm per 10 cfs. Assumes sufficient mixing.

Settling pond capacity (450 cfs) based on max average flow rate sustained over 10-day period, starting with fully dredged pond, until floc accumulation exceeds 1.5 hr detention time requirement at 300 cfs, without dredging.

Dredging capacity (333 cfs) based on each dredge (2) pumping at 900 gpm capacity for eight hours per day, and that such capacity just balances out floc production assuming dredge mix is 50% floc by volume.

Floc Conveyance & Storage capacity based on doubling dredge pipe capacity to handle full 900 gpm output of two dredges.

Dewatering capacity (148 cfs) based on 800 gpm of dredge material (50% floc) throughput of two centrifuges each operating eight hours per day.

Sludge Handling capacity (99 cfs) based on reported output of 18 cy sludge from centrifuge when operating continuously at 400 gpm for eight hours, and staff reported capability to dispose 24 cy on site per eight hour shift.

Progress to Date




1. Continue with Dredging System Improvements




2. Implement automated screening system at Primary Inflow Station



3. Implement Alum Injection improvements, including real-time control



4. Then, assess Dewatering System to determine necessary improvements



5. Defer Sludge Handling improvements to align with off-site disposal needs

Estimated Cost of Capital Improvements

| | |
|-----------------|--------------------|
| Inflow Station | \$1,545,000 |
| Alum Injection | \$359,000 |
| Dredging | \$621,466 |
| Floc Conveyance | \$250,075 |
| Dewatering | None yet. |
| Sludge Handling | None yet. |
| Instrumentation | \$195,000 |
| TOTALS | \$2,971,000 |

Total Represents
Net Savings of \$1.5M
by avoiding capital cost of
second centrifuge
(estimated at \$2.6M).

Additional Operational Improvements

Add Technical Resources to Meet Varying Needs and Conditions

- ▶ Five dedicated staff members
 - On-site Plant Manager with 30 years experience
 - Chief Operator
 - Three O&M Technicians
- ▶ Additional support available 24/7 as needed
 - Innovation Team
 - Health & Safety
 - Maintenance Specialists
 - Controls and Automation
 - Engineering
- ▶ **Enables emphasis on water quality and efficient, sustainable operation.**



Implement Technology to Improve Cost-Effectiveness

- ▶ Implement Geospatial Asset Management Plan
- ▶ Implement Operational Data Management System
- ▶ Equip and train staff to test and monitor water quality daily
- ▶ Track maintenance expenses with focus on cost controls
- ▶ Monthly Operating Reports to LCWA



Create a Safer Working Environment

- ▶ Machine guarding of rotating parts
- ▶ Life rings for ponds and tanks
- ▶ Proper (GHS) labeling of chemical totes
- ▶ Flammable-resistant fuel storage
- ▶ Emergency lighting
- ▶ Shower and eye wash stations
- ▶ Lockout/tagout
- ▶ Arc flash analysis (NFPA 70E)
- ▶ Qualified electrical worker training



Foster Staff Growth Opportunities

- ▶ Improve technical skills: training equipment operators to be water quality technicians
- ▶ Safer working environment
- ▶ Career path, mentoring, and professional development
- ▶ Ownership opportunities



Operational investments improve life cycle costs.

**Additional
Resources**

Technology

**Health &
Safety**

**Professional
Growth**